


BP Cherry Point Cogeneration



CO maximum 8-hour concentration (ug/m3)
 No refinery emission reductions
 Maximum over 5-year period
 ISC-Prime model

US SIL	500
US AAQS	10,000
Canadian Objective (most stringent)	5,500