BP Cherry Point Cogeneration



NOx maximum annual concentration (ug/m3)
No refinery emission reductions
Maximum over 5-year period
ISC-Prime model

US SIL	1
US AAQS	100
Canadian Objective (most stringent)	60