

TABLE II-18

Status of HWCTR (U Area)

	<i>Status</i>
<u>Building 710-U</u>	
(Unirradiated fuel storage)	All HWCTR unirradiated fuel removed.
<u>Reactor Building</u>	
Reactor system	Drained, dried, closed, and filled with N <sub>2</sub> . N <sub>2</sub> makeup discontinued.
Irradiated components	
Fuel and targets	Removed, stored elsewhere
Control, safety, and miscellaneous rods	Left in reactor.
D <sub>2</sub> O coolant	Deionized and returned to 400 Area.
Surface deposits	In situ.
H <sub>2</sub> O systems	Drained; system isolated from well water supply.
Floors	Cleaned to <5 mR/hr.
Purification	
Filters and deionizers	Sent to burial ground.
Spent fuel basin	
Stored fuel	All removed.
Water	Deionized and drained.
Basin	Covered with tarpaulin and wooden cover.
Filters and deionizer	Sent to burial ground.